

Delhi Development Authority

Electrical Division No. – 11

Schedule of work

Name of work:- M/O Various scheme under N/A-II(SEZ).SH: Providing temporary lighting & PA system i/c D.G. set on Hire Basis at Dhobi Ghat (Batla house), Pantoon Pul (Nagli Sarai),Taimoor Nagar Extn. and 4A DDA park, Javjiwan Camp for Chat Puja Celebration

S. No.	Description of item	Qty	Unit	Rate	Amount
1.	Hire charge of MS pole 40mm dia, 18 ft. height including erection dismantling , cartage, loading & unloading as per terms and condition attached etc complete as reqd.	344	Each		
2.	Hire charges of following electric lighting fitting including bulbs & accessories, erection, dismantling ,loading & unloading as per terms and conditions attached etc complete as reqd.				
	a) 400 watt metal halide flood light fitting.	124	Each		
	b) 500 watt halogen flood light fitting.	440	Each		
3.	Hire charges of suitable distribution boards for distributions of circuit over the entire area for controlling lights, sound system and DG set etc complete as reqd.	8	Each		
4.	Hire charges of PA system comprising the 10 Nos Horn 3 Nos Mike, batteries connecting wires including erection dismantling, cartage, loading unloading as per terms and conditions attached etc complete as reqd.	4	Job		

5.	Hire charges of portable type DG set of following capacity including installation, dismantling , diesel, oil cartage, loading , unloading as per terms and conditions attached etc complete as reqd.				
	a) 62.5 KVA DG set.	4	Each		
6.	Hire charges of wiring for operating the complete installation spreaded over 3100 mtr (Aorix.) including laying connection, dismantling, cartage, loading unloading testing as per terms and conditions attached etc complete as reqd. (3100X8=2480 mtr)	1	Job		

ADDITIONAL CONDITION

- etc.
- agency.
1. The item is inclusive of installation, operation, dismantling, cartage
 2. Diesel & operational staff for operation of DG sets shall be of the
 3. Entire installation i/c DG set shall be completed by afternoon of 19.11.2012 and illumination effect & testing shall be done in the evening on same day. The timing of light shall be 5PM to 11PM on 19.11.2012 and 3.30 AM to 6.30 AM on 20.11.2012.
 4. Nothing extra shall be paid to the contractor for any tax or levies.
 5. Entire installation shall be earthed by suitable method, required safety precaution shall be taken by the agency.
 6. During the period of function i.e afternoon onwards of 19.11.2012 till completion of the function sufficient maintenance staff & spare material should available at site to meet the emergency requirement. The cost of which is inclusive in the individual item.
 7. During the period of contract any loss or damage to the property/persons shall be responsibility of the contractor.
 8. No T&P shall be issued by the Department.
 9. Before quoting the rates site of work should be inspected by the agency.
 10. The firm shall be registered with EPFO/FSIC department being labour involvement